

Used Generator Information

Asset Data Information	
Stock Number	XP100013
Set Manufacturer	Broadcrown
Set Model	BCD1000
Set Serial Number	NA
Year Of Manufacture	NA
Price	£3,500.00
Date Into Stock	NA
Alternator Data	
kVA	1000
kW	800
Volts	415/240
Hz	50
Amps	1599
Make	Newage Stamford
Model	HC634D
Serial No:	W4988/01
RCD	No
MCB ACB	ACB
PMG AREP	PMG
Heater	No
Engine Data	
Make	Dorman
Model	12STCAR3
Serial No:	121323 / 0189 / 002
Hours	Less than 1000
Exhaust	No
Bellows	Yes
Voltage	24V
Batteries / Battery Type	No
Battery Isolator	No
Water Jacket Heater	No
Lube oil top up	No
Racor Filter	No
3 Way Fuel Valve	No
Fuel Tank Data	
Skid / Free Standing	No
Single Skin / Bunded	No
Capacity Litres	No
Capacity Hours @ 75%	No
Fuel Gauge	No
Transfer Pump	No
Enclosure Data	
Open / Skid	Open
Sound Attenuated	No
Containerised	No
Sound Level 75% @ 1m	NA
Length mm	4800
Width mm	1850
Height mm (excl exhaust)	2500
Height mm (incl exhaust)	2500
Colour	Blue
Condition	Used
Lighting AC / DC	No
Bunded Floor	No
Lifting Data / Chassis	
Weight Kg	No
Corner / Centre Point	Corner Lifting
Forklift Pockets	No
Trailer	No
Control Panel Data	
Make	No
LED / Analog	No
Hour Meter	No
Oil	Yes
Water	Yes
Battery	No
Amp	Yes
Volts	No
Hz	No
AMF - Parallel	No
Battery Charger	No
Additional Data	
Sockets	NA

1 Side bank missing heads - outlet manifold - part of fuel injection pump missing



All Diesel Generators Are Inspected And Tested Prior To Dispatch