

Table 20: 400 V, 50 Hz, 3-phase

Rated power, kW	Rated power, hp	Curve/ Impeller No	Revolutions per minute, rpm	Rated current, A	Starting current, A	Power factor, cos φ	Installation
2.4	3.2	421	1460	5.7	40	0.71	T,Z
2.4	3.2	423	1460	5.7	40	0.71	T,Z
3.1	4.2	420	1450	6.8	40	0.78	P,S
3.1	4.2	421	1450	6.8	40	0.78	P,S
3.1	4.2	423	1450	6.8	40	0.78	P,S

MT




Table 21: 400 V, 50 Hz, 3-phase

Rated power, kW	Rated power, hp	Curve/ Impeller No	Revolutions per minute, rpm	Rated current, A	Starting current, A	Power factor, cos φ	Installation
2.4	3.2	462	1460	5.7	40	0.71	T,Z
2.4	3.2	463	1460	5.7	40	0.71	T,Z
2.4	3.2	464	1460	5.7	40	0.71	T,Z
3.1	4.2	460	1450	6.8	40	0.78	P,S
3.1	4.2	461	1450	6.8	40	0.78	P,S
3.1	4.2	462	1450	6.8	40	0.78	P,S
3.1	4.2	463	1450	6.8	40	0.78	P,S
3.1	4.2	464	1450	6.8	40	0.78	P,S